



Cal Fire - Improved Parcel Inspection Worksheet

- Clean
Needs Work
Severe

Owner:

Mailing Address:

Property Address:

Property address input box

Subdivision:

Blue Lake Springs

Repeat Offender checkbox

Unit/Lot:

Unit/Lot input box

Inspector:

Previous Year

Comments:

STRUCTURE(S):

- Address numbers: Numbers must be displayed in contrasting colors (4" Min. Size) and readable from the street or access road. CFC 505.1
Propane tanks: REMOVE all flammable material and vegetation 10 feet around and above. Large trees may remain. Non-volatile vegetation or decorative enclosures are allowed if they do not hide the tank's location from firefighters, or impede firefighters access to the valve assembly. CFC 3807.3
Roofs, gutters, decks, porches, stairways: REMOVE all leaves, needles, branches. PRS 4291(a)(6)
Chimney/stovepipe outlets: REMOVE all branches within 10 feet. PRC 4291(a)(4)
Chimney/stovepipe outlets: COVER with 3/8"-1/2" mesh screen. CBC 2114.9.1

DEFENSIBLE SPACE ZONE (within 30 feet of all structures, including decks and stairways.)

- Dead/dying trees, branches, shrubs, or other plants adjacent to or overhanging buildings: REMOVE all. PRC 4291(a)(5)
Needles, leaves, dead weeds, grass, trimmings: REMOVE completely, including within groundcovers. PRC 4291(a)(1)
Mountain misery/bear clover: REMOVE all.

REDUCED FUEL ZONE (within 30 feet and to 100 feet of all structures, including decks and stairways)

- Dead/dying brush, trees, and all dead branches within 15 feet of the ground: REMOVE completely,
LIVE brush, shrubs, ground-covers, seedling/sapling trees: Thin, prune, and space according to the Horizontal Spacing Standard. PRC 4391(a)(1)
Mature trees: REMOVE dead branches 15 feet from the ground. Prune live branches to a height of 6-15 feet (or 1/3 tree height for trees under 18 feet). Prune higher on slopes and where there is underlying vegetation.
Logs or stumps embedded in the soil: REMOVE or ISOLATE from structures and other vegetation.
Woodpiles: CLEAR 10 feet around and 15 feet above. Recommend moving as far as possible from structures and covering with fire resistant material.
Non-vegetative flammable material: REMOVE or CLEAR around and cover with fire-resistant tarp.
Mountain/bear clover between 30 and 100 feet from structures: Maintain at 4" or less and remove overhanging branches within 15 feet.
Dead grass/weeds between 30 and 100 feet from structures: Cut to max 4 inches in height; trimmings may stay on the ground.

Comments:

Comments input lines